

LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	065F	Room B313 Sink-F	CF	COPPER	0.014	MG/L	0.003	EPA 200.7	NASHO BA	171073 95		RT	9/27/2016	07:16:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	065F	Room B313 Sink-F	CF	LEAD	0.002	MG/L	0.001	SM 3113B	NASHO BA	171073 95		RT	9/27/2016	07:16:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	065P	Room B313 Sink-P	CF	COPPER	0.038	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 94		RT	9/27/2016	07:15:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	065P	Room B313 Sink-P	CF	LEAD	0.005	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 94		RT	9/27/2016	07:15:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	066P	Room B309 Bubbler-P	DW	COPPER	0.039	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 96		RT	9/27/2016	07:17:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	066P	Room B309 Bubbler-P	DW	LEAD	0.076	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 96		RT	9/27/2016	07:17:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	067F	Room B309 Sink-F	CF	COPPER	0.005	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 98		RT	9/27/2016	07:18:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	067F	Room B309 Sink-F	CF	LEAD	0.001	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 98		RT	9/27/2016	07:18:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	067P	Room B309 Sink-P	CF	COPPER	0.048	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 97		RT	9/27/2016	07:17:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	067P	Room B309 Sink-P	CF	LEAD	0.007	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 97		RT	9/27/2016	07:17:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	068P	Room B312 Bubbler-P	DW	COPPER	0.036	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 99		RT	9/27/2016	07:19:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	068P	Room B312 Bubbler-P	DW	LEAD	0.076	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 99		RT	9/27/2016	07:19:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	069F	Room B312Sink-F	CF	COPPER	0.004	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 101		RT	9/27/2016	07:20:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	069F	Room B312Sink-F	CF	LEAD	0.002	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 101		RT	9/27/2016	07:20:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	069P	Room B312Sink-P	CF	COPPER	0.021	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 100		RT	9/27/2016	07:19:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	069P	Room B312Sink-P	CF	LEAD	0.016	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 100		RT	9/27/2016	07:19:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	070F	Water Cooler in C Building/Girls Lock-F	WC	COPPER	0.029	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 103		RT	9/27/2016	07:28:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	070F	Water Cooler in C Building/Girls Lock-F	WC	LEAD	ND	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 103		RT	9/27/2016	07:28:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	070P	Water Cooler in C Building/Girls Lock-P	WC	COPPER	0.026	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 102		RT	9/27/2016	07:27:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	070P	Water Cooler in C Building/Girls Lock-P	WC	LEAD	ND	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 102		RT	9/27/2016	07:27:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	072F	C Building Gym Bubbler/Farthest from-F	DW	COPPER	0.29	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 105		RT	9/27/2016	07:33:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	072F	C Building Gym Bubbler/Farthest from-F	DW	LEAD	ND	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 105		RT	9/27/2016	07:33:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	072P	C Building Gym Bubbler/Farthest from-P	DW	COPPER	0.58	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 104		RT	9/27/2016	07:32:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	072P	C Building Gym Bubbler/Farthest from-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 104		RT	9/27/2016	07:32:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	073F	Gym Office Sink/Close to Stage-F	CF	COPPER	0.033	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 107		RT	9/27/2016	07:30:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	073F	Gym Office Sink/Close to Stage-F	CF	LEAD	ND	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 107		RT	9/27/2016	07:30:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	073P	Gym Office Sink/Close to Stage-P	CF	COPPER	0.038	MG/L	0.003	EPA 200.7	ANALYTI NASHO BA	171073 106		RT	9/27/2016	07:30:00	11-Oct-16
LCCA	Lawrence	01490525	Lawrence: Frost Middle School	Public School	073P	Gym Office Sink/Close to Stage-P	CF	LEAD	ND	MG/L	0.001	SM 3113B	ANALYTI NASHO BA	171073 106		RT	9/27/2016	07:30:00	11-Oct-16