

The results (column H) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

CITYTOWN	ORG CODE	SCHOOL NAME	LOCATION ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	001F	Front Entrance Bubbler-F	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170906 2	AD	9/21/2016	06:17:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	001F	Front Entrance Bubbler-F	DW	COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170906 2	AD	9/21/2016	06:17:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	001P	Front Entrance Bubbler-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170906 1	AD	9/21/2016	06:16:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	001P	Front Entrance Bubbler-P	DW	COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170906 1	AD	9/21/2016	06:16:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	002F	Nurse Sink in Office-F	NS	LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170906 4	AD	9/21/2016	06:28:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	002F	Nurse Sink in Office-F	NS	COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170906 4	AD	9/21/2016	06:28:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	002P	Nurse Sink in Office-P	NS	LEAD	0.004	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170906 3	AD	9/21/2016	06:27:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	002P	Nurse Sink in Office-P	NS	COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170906 3	AD	9/21/2016	06:27:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	003F	2nd Floor Bubbler-F	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170906 6	AD	9/21/2016	06:23:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	003F	2nd Floor Bubbler-F	DW	COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170906 6	AD	9/21/2016	06:23:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	003P	2nd Floor Bubbler-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170906 5	AD	9/21/2016	06:22:00	27-Sep-16
Lawrence	01490002	Lawrence: Lawlor Early Childhood Center	003P	2nd Floor Bubbler-P	DW	COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170906 5	AD	9/21/2016	06:22:00	27-Sep-16