

The results (column H) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

| CITY TOWN | ORG CODE | SCHOOL NAME | LOCATION ID | SAMPLE LOCATION NAME | SAMPLE COMMENTS | ANALYTE NAME | RESULT | UNITS OF MEASUREMENT | METHOD DETECTION LIMIT | ANALYTICAL METHOD USED | ANALYSIS LAB | LAB SAMPLE ID | ANALYSIS COMMENTS | SAMPLER NAME | SAMPLE COLLECTION DATE | SAMPLE COLLECTION TIME | REPORT DATE |
|-----------|----------|--|-------------|--------------------------|-----------------|--------------|--------|----------------------|------------------------|------------------------|------------------------|---------------|-------------------|--------------|------------------------|------------------------|-------------|
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 001F | Nurse Room Sink-F | NS | LEAD | 0.007 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 2 | | AD | 9/22/2016 | 05:55:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 001F | Nurse Room Sink-F | NS | COPPER | 0.03 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 2 | | AD | 9/22/2016 | 05:55:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 001P | Nurse Room Sink-P | NS | LEAD | 0.02 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 1 | | AD | 9/22/2016 | 05:54:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 001P | Nurse Room Sink-P | NS | COPPER | 0.061 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 1 | | AD | 9/22/2016 | 05:54:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 002F | 1st Floor Water Cooler-F | WC | LEAD | 0.004 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 4 | | AD | 9/22/2016 | 05:56:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 002F | 1st Floor Water Cooler-F | WC | COPPER | 0.068 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 4 | | AD | 9/22/2016 | 05:56:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 002P | 1st Floor Water Cooler-P | WC | LEAD | 0.003 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 3 | | AD | 9/22/2016 | 05:55:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 002P | 1st Floor Water Cooler-P | WC | COPPER | 0.077 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 3 | | AD | 9/22/2016 | 05:55:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 003F | Kitchen Food Prep Sink-F | KC | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 6 | | AD | 9/22/2016 | 05:58:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 003F | Kitchen Food Prep Sink-F | KC | COPPER | 0.023 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 6 | | AD | 9/22/2016 | 05:58:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 003P | Kitchen Food Prep Sink-P | KC | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 5 | | AD | 9/22/2016 | 05:57:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 003P | Kitchen Food Prep Sink-P | KC | COPPER | 0.068 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 5 | | AD | 9/22/2016 | 05:57:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 004F | Kitchen Coffee Machine-F | OT | LEAD | 0.032 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 8 | | RJ | 9/22/2016 | 05:58:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 004F | Kitchen Coffee Machine-F | OT | COPPER | 0.436 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 8 | | RJ | 9/22/2016 | 05:58:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 004P | Kitchen Coffee Machine-P | OT | LEAD | 0.023 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 7 | | AD | 9/22/2016 | 05:58:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 004P | Kitchen Coffee Machine-P | OT | COPPER | 0.239 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 7 | | AD | 9/22/2016 | 05:58:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 005F | Sink Outside Room 5-F | OT | LEAD | 0.008 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 10 | | RJ | 9/22/2016 | 06:02:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 005F | Sink Outside Room 5-F | OT | COPPER | 0.121 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 10 | | RJ | 9/22/2016 | 06:02:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 005P | Sink Outside Room 5-P | OT | LEAD | 0.005 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 9 | | RJ | 9/22/2016 | 06:01:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 005P | Sink Outside Room 5-P | OT | COPPER | 0.119 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 9 | | RJ | 9/22/2016 | 06:01:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 007F | 3rd Floor Water Cooler-F | WC | LEAD | 0.006 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 12 | | AD | 9/22/2016 | 06:05:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 007F | 3rd Floor Water Cooler-F | WC | COPPER | 0.112 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 12 | | AD | 9/22/2016 | 06:05:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 007P | 3rd Floor Water Cooler-P | WC | LEAD | 0.006 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 11 | | AD | 9/22/2016 | 06:04:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 007P | 3rd Floor Water Cooler-P | WC | COPPER | 0.128 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 11 | | AD | 9/22/2016 | 06:04:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 008F | Teacher's Room Faucet-F | CF | LEAD | 0.003 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 14 | | AD | 9/22/2016 | 06:09:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 008F | Teacher's Room Faucet-F | CF | COPPER | 0.024 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 14 | | AD | 9/22/2016 | 06:09:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 008P | Teacher's Room Faucet-P | CF | LEAD | 0.03 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | 170911 13 | | AD | 9/22/2016 | 06:06:00 | 27-Sep-16 |
| Lawrence | 01490011 | Lawrence: Lawrence Family Public Academy | 008P | Teacher's Room Faucet-P | CF | COPPER | 0.079 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | 170911 13 | | AD | 9/22/2016 | 06:06:00 | 27-Sep-16 |