

The results (column H) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

| CITY/TOWN | ORG CODE | SCHOOL NAME | LOCATION ID | SAMPLE LOCATION NAME | SAMPLE COMMENTS | ANALYTE NAME | RESULT | UNITS OF MEASUREMENT | METHOD DETECTION LIMIT | ANALYTICAL METHOD USED | ANALYSIS LAB | ANALYSIS COMMENTS | SAMPLER NAME | SAMPLE COLLECTION DATE | SAMPLE COLLECTION TIME | REPORT DATE |
|-----------|----------|-------------------------------------|-------------|--|-----------------|--------------|--------|----------------------|------------------------|------------------------|------------------------|-------------------|--------------|------------------------|------------------------|-------------|
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 001F | Nurse Room Sink-F | NS | COPPER | ND | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:28:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 001F | Nurse Room Sink-F | NS | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:28:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 001P | Nurse Room Sink-P | NS | COPPER | 0.06 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:27:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 001P | Nurse Room Sink-P | NS | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:27:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 002F | Teacher's Room/Room 105 Sink-F | CF | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:29:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 002F | Teacher's Room/Room 105 Sink-F | CF | COPPER | ND | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:29:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 002P | Teacher's Room/Room 105 Sink-P | CF | COPPER | ND | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:28:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 002P | Teacher's Room/Room 105 Sink-P | CF | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:28:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 003F | Basement Boys Bathroom Bubbler-F | DW | COPPER | 0.011 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:33:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 003F | Basement Boys Bathroom Bubbler-F | DW | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:33:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 003P | Basement Boys Bathroom Bubbler-P | DW | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:32:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 003P | Basement Boys Bathroom Bubbler-P | DW | COPPER | 0.016 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:32:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 005F | Basement Girls Bathroom Bubbler/Left-P | DW | COPPER | 0.01 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | AD | 9/21/2016 | 07:31:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 005F | Basement Girls Bathroom Bubbler/Left-P | DW | LEAD | 0.002 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | AD | 9/21/2016 | 07:31:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 005P | Basement Girls Bathroom Bubbler/Ri-P | DW | COPPER | 0.015 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | AD | 9/21/2016 | 07:30:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 005P | Basement Girls Bathroom Bubbler/Ri-P | DW | LEAD | 0.016 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | AD | 9/21/2016 | 07:30:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 006F | Music Room Basement Sink-F | CF | LEAD | ND | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:36:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 006F | Music Room Basement Sink-F | CF | COPPER | ND | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:36:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 006P | Music Room Basement Sink-P | CF | COPPER | 0.027 | MG/L | 0.003 | EPA 200.7 | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:35:00 | 27-Sep-16 |
| Lawrence | 01490048 | Lawrence: Oliver Partnership School | 006P | Music Room Basement Sink-P | CF | LEAD | 0.007 | MG/L | 0.001 | SM 3113B | NASHOBA ANALYTICAL LLC | | RJ | 9/21/2016 | 07:35:00 | 27-Sep-16 |