

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect; the contaminant was not detected above the MDL.

REPORTTYPE/CODE	CITY/TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTENAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	LAB COLLECTION TIME	REPORT DATE
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	002F	Kitchen Food Prep Sink-F	KC	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 2		RT	9/23/2016	06:31:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	002F	Kitchen Food Prep Sink-F	KC	COPPER	0.016	MG/L	0.003	EPA 200.7	NASHOB 170912 2		RT	9/23/2016	06:31:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	002P	Kitchen Food Prep Sink-P	KC	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 1		RT	9/23/2016	06:30:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	002P	Kitchen Food Prep Sink-P	KC	COPPER	0.033	MG/L	0.003	EPA 200.7	NASHOB 170912 1		RT	9/23/2016	06:30:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	004F	Kitchen Kettle Right-F	KK	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 4		RT	9/23/2016	06:32:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	004F	Kitchen Kettle Right-F	KK	COPPER	0.024	MG/L	0.003	EPA 200.7	NASHOB 170912 4		RT	9/23/2016	06:32:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	004P	Kitchen Kettle Right-P	KK	COPPER	0.065	MG/L	0.003	EPA 200.7	NASHOB 170912 3		RT	9/23/2016	06:31:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	004P	Kitchen Kettle Right-P	KK	LEAD	0.003	MG/L	0.001	SM 3113B	NASHOB 170912 3		RT	9/23/2016	06:31:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	005F	Kitchen Kettle Left-F	KK	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 6		RT	9/23/2016	06:34:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	005F	Kitchen Kettle Left-F	KK	COPPER	0.021	MG/L	0.003	EPA 200.7	NASHOB 170912 6		RT	9/23/2016	06:34:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	005P	Kitchen Kettle Left-P	KK	COPPER	0.064	MG/L	0.003	EPA 200.7	NASHOB 170912 5		RT	9/23/2016	06:33:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	005P	Kitchen Kettle Left-P	KK	LEAD	0.002	MG/L	0.001	SM 3113B	NASHOB 170912 5		RT	9/23/2016	06:33:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	006F	Double Bay Food Prep Sink-F	KC	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 8		RT	9/23/2016	06:35:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	006F	Double Bay Food Prep Sink-F	KC	COPPER	0.018	MG/L	0.003	EPA 200.7	NASHOB 170912 8		RT	9/23/2016	06:35:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	006P	Double Bay Food Prep Sink-P	KC	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 7		RT	9/23/2016	06:34:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	006P	Double Bay Food Prep Sink-P	KC	COPPER	0.041	MG/L	0.003	EPA 200.7	NASHOB 170912 7		RT	9/23/2016	06:34:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	007P	Bubbler by Care/Shipping Left-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 9		RT	9/23/2016	06:36:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	007P	Bubbler by Care/Shipping Left-P	DW	COPPER	0.039	MG/L	0.003	EPA 200.7	NASHOB 170912 9		RT	9/23/2016	06:36:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	008F	Bubbler by Care/Shipping Right-F	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 11		RT	9/23/2016	06:37:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	008F	Bubbler by Care/Shipping Right-F	DW	COPPER	0.044	MG/L	0.003	EPA 200.7	NASHOB 170912 11		RT	9/23/2016	06:37:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	008P	Bubbler by Care/Shipping Right-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 10		RT	9/23/2016	06:36:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	008P	Bubbler by Care/Shipping Right-P	DW	COPPER	0.044	MG/L	0.003	EPA 200.7	NASHOB 170912 10		RT	9/23/2016	06:36:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	009F	1st Floor Computer Room Sink-F	CF	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 13		RT	9/23/2016	07:14:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	009F	1st Floor Computer Room Sink-F	CF	COPPER	0.025	MG/L	0.003	EPA 200.7	NASHOB 170912 13		RT	9/23/2016	07:14:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	009P	1st Floor Computer Room Sink-P	CF	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 12		RT	9/23/2016	07:13:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	009P	1st Floor Computer Room Sink-P	CF	COPPER	0.13	MG/L	0.003	EPA 200.7	NASHOB 170912 12		RT	9/23/2016	07:13:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	010P	Bubbler by T-11 left-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 14		RT	9/23/2016	06:39:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	010P	Bubbler by T-11 left-P	DW	COPPER	0.079	MG/L	0.003	EPA 200.7	NASHOB 170912 14		RT	9/23/2016	06:39:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	011F	Bubbler by T-11 right-F	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 16		RT	9/23/2016	06:40:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	011F	Bubbler by T-11 right-F	DW	COPPER	0.057	MG/L	0.003	EPA 200.7	NASHOB 170912 16		RT	9/23/2016	06:40:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	011P	Bubbler by T-11 right-P	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 15		RT	9/23/2016	06:39:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	011P	Bubbler by T-11 right-P	DW	COPPER	0.08	MG/L	0.003	EPA 200.7	NASHOB 170912 15		RT	9/23/2016	06:39:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	012P	Art Room Sink closest to door left-P	CF	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 17		RT	9/23/2016	07:17:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	012P	Art Room Sink closest to door left-P	CF	COPPER	0.063	MG/L	0.003	EPA 200.7	NASHOB 170912 17		RT	9/23/2016	07:17:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	013F	Art Room Sink closest to door right-F	CF	COPPER	0.05	MG/L	0.003	EPA 200.7	NASHOB 170912 19		RT	9/23/2016	07:18:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	013F	Art Room Sink closest to door right-F	CF	LEAD	0.001	MG/L	0.001	SM 3113B	NASHOB 170912 19		RT	9/23/2016	07:18:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	013P	Art Room Sink closest to door right-P	CF	COPPER	0.075	MG/L	0.003	EPA 200.7	NASHOB 170912 18		RT	9/23/2016	07:18:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	013P	Art Room Sink closest to door right-P	CF	LEAD	0.003	MG/L	0.001	SM 3113B	NASHOB 170912 18		RT	9/23/2016	07:18:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	014P	Art Room Sink farthest from door left-P	CF	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 20		RT	9/23/2016	07:19:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	014P	Art Room Sink farthest from door left-P	CF	COPPER	0.054	MG/L	0.003	EPA 200.7	NASHOB 170912 20		RT	9/23/2016	07:19:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	015F	Art Room Sink farthest from door right-F	CF	COPPER	0.044	MG/L	0.003	EPA 200.7	NASHOB 170912 22		RT	9/23/2016	07:19:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	015F	Art Room Sink farthest from door right-F	CF	LEAD	0.002	MG/L	0.001	SM 3113B	NASHOB 170912 22		RT	9/23/2016	07:19:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	015P	Art Room Sink farthest from door right-P	CF	COPPER	0.047	MG/L	0.003	EPA 200.7	NASHOB 170912 21		RT	9/23/2016	07:19:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	015P	Art Room Sink farthest from door right-P	CF	LEAD	0.008	MG/L	0.001	SM 3113B	NASHOB 170912 21		RT	9/23/2016	07:19:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	016F	1st Floor Teacher Room Sink-F	CF	COPPER	0.016	MG/L	0.003	EPA 200.7	NASHOB 170912 24		RT	9/23/2016	06:43:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	016F	1st Floor Teacher Room Sink-F	CF	LEAD	0.008	MG/L	0.001	SM 3113B	NASHOB 170912 24		RT	9/23/2016	06:43:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	016P	1st Floor Teacher Room Sink-P	CF	COPPER	0.04	MG/L	0.003	EPA 200.7	NASHOB 170912 23		RT	9/23/2016	06:42:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	016P	1st Floor Teacher Room Sink-P	CF	LEAD	0.074	MG/L	0.001	SM 3113B	NASHOB 170912 23		RT	9/23/2016	06:42:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	017P	Room 120 Faucet-P	CF	COPPER	3.34	MG/L	0.003	EPA 200.7	NASHOB 170912 25		RT	9/23/2016	06:55:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	017P	Room 120 Faucet-P	CF	LEAD	0.022	MG/L	0.001	SM 3113B	NASHOB 170912 25		RT	9/23/2016	06:55:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	018F	Room 120 Bubbler-F	DW	COPPER	0.24	MG/L	0.003	EPA 200.7	NASHOB 170912 27		RT	9/23/2016	06:56:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	018F	Room 120 Bubbler-F	DW	LEAD	0.002	MG/L	0.001	SM 3113B	NASHOB 170912 27		RT	9/23/2016	06:56:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	018P	Room 120 Bubbler-P	DW	COPPER	0.79	MG/L	0.003	EPA 200.7	NASHOB 170912 26		RT	9/23/2016	06:55:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	018P	Room 120 Bubbler-P	DW	LEAD	0.086	MG/L	0.001	SM 3113B	NASHOB 170912 26		RT	9/23/2016	06:55:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	019P	Room 117 Faucet-P	CF	COPPER	2.81	MG/L	0.003	EPA 200.7	NASHOB 170912 28		RT	9/23/2016	06:57:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	019P	Room 117 Faucet-P	CF	LEAD	0.013	MG/L	0.001	SM 3113B	NASHOB 170912 28		RT	9/23/2016	06:57:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	020F	Room 117 Faucet-F	DW	LEAD	ND	MG/L	0.001	SM 3113B	NASHOB 170912 29		RT	9/23/2016	06:58:00	29-Sep-16	
LCCA	Lawrence	01490004	Lawrence: South Lawrence East Elementary	Public School	020F	Room 117 Faucet-F	DW	COPPER	0.069	MG/L	0.003	EPA 200.7	NASHOB 170912 29		RT	9/23/2016	06:58:00	29-Sep-16	



